

Final Project Assessment Report

7 September 2021

Version 1.0

Coomera-Pimpama Network Limitation



Part of the Energy Queensland Group

Disclaimer

While care was taken in preparation of the information in this Non Network Options Report, and it is provided in good faith, Energex Limited accepts no responsibility or liability for any loss or damage that may be incurred by any person acting in reliance on this information or assumptions drawn from it. This document has been prepared for the purpose of inviting information, comment and discussion from interested parties. The document has been prepared using information provided by a number of third parties. It contains assumptions regarding, among other things, economic growth and load forecasts which may or may not prove to be correct. All information should be independently verified to the extent possible before assessing any investment proposal.

EXECUTIVE SUMMARY

ABOUT ENERGEX

Energex is a subsidiary of Energy Queensland Limited, a Queensland Government Owned Corporation. Energex distributes electricity to over 1.5 million residential, commercial and industrial customers across a population base of around 3.4 million in South East Queensland.

IDENTIFIED NEED

Coomera zone substation (SSCMA) and Pimpama East Zone Substation (SSPPE) are both supplied from Coomera bulk supply substation (SSCMA BSP). SSCMA and SSPPE provide electricity supply to approximately 21,400 predominately domestic customers in the areas of Coomera, Jacobs Well, Norwell, Ormeau, Pimpama, Steiglitz, Upper Coomera, Willow Vale, and Woongoolba. With new developments in the Coomera and Pimpama areas, loads are forecast to increase significantly causing network limitations in the area.

The identified need for this Final Project Assessment Report (FPAR) is that Energex will not meet its Safety Net obligation as outlined in its Distribution Authority at SSCMA in the summer of 2020/21 and SSPPE in the summer of 2022/23 due to load growth in the area. The requirements of a non-network option to solve the identified need are summarised in Table 1 and Table 2 below.

Substation	Year	Forecast 50 PoE Load (MVA)	Security Standard Load At Risk (MVA)	Days/Yr Above Limit	% Time Above Limit	Hrs Over Limit
SSCMA (Coomera Zone Substation)	2020/21	45.3	1.5	1	0.03%	2.5
	2021/22	46.0	2.2	1	0.05%	4
	2022/23	46.8	3.0	2	0.06%	5.5
	2023/24	47.2	3.4	2	0.07%	6.5
	2024/25	47.8	4.0	3	0.09%	8
	2025/26	48.4	4.6	3	0.11%	9.5
	2026/27	49.0	5.2	5	0.15%	13.5
	2027/28	50.2	6.4	7	0.21%	18.5
	2028/29	51.2	7.4	9	0.31%	27
	2029/30	52.5	8.7	9	0.41%	35.5

Table 1: Non-network Option Requirements for SSCMA

Substation	Year	Forecast 50 PoE Load (MVA)	Security Standard Load At Risk (MVA)	Days/Yr Above Limit	% Time Above Limit	Hrs Over Limit
SSPPE (Pimpama East zone substation)	2020/21	32.0	0.0	-	-	-
	2021/22	33.2	0.0	-	-	-
	2022/23	34.6	0.8	1	0.02%	1.5
	2023/24	35.8	2.0	2	0.05%	4
	2024/25	36.9	3.1	4	0.09%	7.5
	2025/26	38.1	4.3	4	0.13%	11.5
	2026/27	39.4	5.6	6	0.21%	18
	2027/28	41.0	7.2	9	0.33%	28.5
	2028/29	42.5	8.7	12	0.45%	39.5
	2029/30	44.2	10.4	17	0.65%	57

Table 2: Non-network Option Requirements for SSPPE

As part of its operational strategy following a contingency, Energex will deploy 4MVA of generation using its fleet of mobile generators. In addition to the requirements above, Energex would be interested in any network support solutions that provide a cost-effective alternative to this requirement.

APPROACH

The National Electricity Rules (NER) require that, subject to certain exclusion criteria, network business investments for meeting service standards for a distribution business are subject to a Regulatory Investment Test for Distribution (RIT-D). Energex has determined that investment is essential in this case for it to meet the Safety Net criteria established in its Distribution Authority. Accordingly, this investment is subject to a RIT-D.

In order to eliminate the load at risk and satisfy the Safety Net obligations, Energex has identified several network options to address the limitations identified, as below:

- Option 1: Establish new 25MVA 33/11kV Pimpama zone substation
- Option 2: Establish new 25MVA 33/11kV Coomera East zone substation
- Option 3: Upgrade Coomera zone substation by installing a 3rd 25MVA 33/11kV transformer and associated switchgear

Energex published a Draft Project Assessment Report (DPAR) for the above described network constraint on 4 May 2021. Two submissions were received by the closing date of 15 June 2021. These submissions identified two feasible options:

- Option 4: Establish multiple Battery Energy Storage Systems on multiple 11kV feeders across SSCMA and SSPPE
- Option 5: Establish multiple Battery Energy Storage Systems on multiple 11kV feeders at SSCMA only

Final Project Assessment Report



This FPAR, where Energex provides both technical and economic information about possible solutions, has been prepared in accordance with the requirements of clause 5.17.4(o) of the NER.

Energex's preferred solution to address the identified need is Option 5 – Establish multiple Battery Energy Storage Systems on multiple 11kV feeders at SSCMA only.

CONTENTS

1.	Introduction	1
1.1.	General Terms and Conditions	Error! Bookmark not defined.
1.2.	Contact Details	Error! Bookmark not defined.
2.	Background	1
2.1.	Existing Network	2
2.1.	Load Profiles	5
3.	Identified Need	7
3.1.	Applied Service Standard	7
3.2.	Description of the Identified Need	8
3.2.1.	Safety Net Non-Compliance	8
3.3.	Quantification of the Identified Need	8
3.3.1.	Safety Net Non-Compliance	8
4.	Network Options Identified	16
4.1.	Do Nothing (Base Case)	16
4.1.1.	Option 1: Establish new 25MVA 33/11kV Pimpama zone substation (SSPPA)	16
4.1.2.	Option 2: Establish new 25MVA 33/11kV Coomera East zone substation (SSCET)	17
4.1.3.	Option 3: Upgrade SSCMA by installing a 3 rd 25MVA 33/11kV transformer and associated switchgear	19
4.2.	Preferred Network Option	20
4.3.	Potential Deferred Augmentation Charge	Error! Bookmark not defined.
5.	Summary of Submissions Received	21
5.1.	Option 4: Contract multiple Battery Energy Storage Systems	21
5.2.	Option 5: Contract a single Battery Energy Storage System connected to SSCMA	22
6.	Non-Network Options	23
6.1.	Assessment of Non-Network Solutions	Error! Bookmark not defined.
6.2.	Feasible vs Non-Feasible Options	23
6.2.1.	Potentially Feasible Options	23
6.2.2.	Options That Are Unlikely To Be Feasible	23
6.2.3.	Timing of Feasible Options	Error! Bookmark not defined.

Final Project Assessment Report



7.	Market Benefit Assessment Methodology.....	24
8.	Detailed Economic Assessment	25
8.1.	Methodology.....	25
8.2.	Key Variables and Assumptions.....	26
8.2.1.	Discount Rate.....	26
8.2.2.	Cost Estimates	26
8.2.3.	Evaluation Test Period	26
8.3.	Scenarios Adopted for Sensitivity Analysis.....	26
8.4.	NPV Results.....	27
8.5.	Selection of Preferred Option	27
9.	Submission and Next Steps	Error! Bookmark not defined.
9.1.	Submission from Solution Providers.....	Error! Bookmark not defined.
9.1.	Next Steps	Error! Bookmark not defined.
9.2.	Next Steps	Error! Bookmark not defined.
10.	Compliance Statement.....	29
	Appendix A – The RIT-D Process	30
	Appendix B – Glossary of Terms.....	31
	Appendix C – NPV Details	33

1. Introduction

This Final Project Assessment Report (FPAR) has been prepared by Energex in accordance with the requirements of clause 5.17.4(o) of the NER.

This report represents the final stage of the consultation process in relation to the application of the RIT-D on potential credible options to address the identified need that Energex will not meet its Safety Net obligation as outlined in its Distribution Authority at SSLGV in the summer of 2020/21 due to load growth in the area.

In preparing this RIT-D, Energex is required to consider reasonable future scenarios. With respect to major customer loads and generation, Energex has, in good faith, included as much detail as possible while maintaining necessary customer confidentiality. Potential large future connections that Energex is aware of are in different stages of progress and are subject to change (including outcomes where none or all proceed). These and other customer activity can occur over the consultation period and may change the timing and/or scope of any proposed solutions.

1.1. Dispute Resolution Process

In accordance with the provisions set out in clause 5.17.5(a) of the NER, Registered Participants or Interested Parties may, within 30 days after the publication of this report, dispute the conclusions made by Energex in this report with the Australian Energy Regulator. Accordingly, Registered Participants and Interested Parties who wish to dispute the conclusions outlined in this report based on a manifest error in the calculations or application of the RIT-D must do so within 30 days of the publication date of this report. Any parties raising a dispute are also required to notify Energex. Dispute notifications should be sent to demandmanagement@energex.com.au.

If no formal dispute is raised, Energex will proceed with the preferred option to establish multiple Battery Energy Storage Systems on multiple 11kV feeders at SSCMA only

1.2. Contact Details

For further information and inquiries please contact:

E: demandmanagement@energex.com.au

P: 13 74 66

2. Background

2.1. Existing Network

Coomera zone substation (SSCMA) and Pimpama East zone substation (SSPPE) provide electricity supply to approximately 11,600 and 9,800 predominately domestic customers in the areas of Coomera, Jacobs Well, Norwell, Ormeau, Pimpama, Steiglitz, Upper Coomera, Willow Vale, and Woongoolba area.

SSCMA and SSPPE are both supplied from Coomera bulk supply substation (SSCMA BSP). There are two 33kV feeders, F3641 and F3642, connecting SSPPE to SSCMA BSP, and with the current loads, each feeder can supply the SSPPE substation load for an outage of the other. Geographic and schematic views of the network area under study are provided in Figure 1, Figure 2, and Figure 3.




Figure 1: Existing sub-transmission network arrangement (Geographic view)

Final Project Assessment Report




Figure 2: Existing 11kV network arrangement (Geographic view)

Final Project Assessment Report




Figure 3: Existing network arrangement (schematic view)

2.1. Load Profiles

The annual load profiles for SSCMA & SSPPE are shown in Figure 4 & Figure 5 below.




Figure 4: Annual load profile (MVA) for SSCMA in 2018/19






Figure 5: Annual load profile (MVA) for SSPPE in 2018/19

Figure 6 & Figure 7 show the load duration curves for SSCMA and SSPPE respectively. These are based on the previous 3 years of data and are scaled to their respective maximum 50% Probability of Exceedance (50PoE) forecasts.



*The values for SSCMA have been scaled to the 2022 peak forecast load of 46.0MVA. 2022 is the year the identified need first appears at SSCMA.

Figure 6: Load duration curve for SSCMA



*The values for SSPPE have been scaled to the 2023 peak forecast load of 34.6MVA. 2023 is the year the identified need first appears at SSPPE.

Figure 7: Load duration curve for SSPPE

3. Identified Need

3.1. Applied Service Standard

Under its Distribution Authority, Energex must adhere to the Safety Net which identifies the principles that apply to the operation of network assets under network contingency conditions. System contingency related capability is assessed against a 50% probability of exceedance (PoE) forecast load, available load transfers, emergency cyclic capacity (ECC) ratings, non-network response, mobile plant, mobile generators, and short-term ratings of plant and equipment where available. This process allows load at risk under contingency conditions to be identified and assessed. Energex's Distribution Authority can be accessed by the following link:

https://www.dnrme.qld.gov.au/_data/assets/pdf_file/0003/219486/distribution-authority-d0798-energex.pdf

SSCMA and SSPPE are classified as Urban substations, and as such, the following Safety Net criteria apply:

- For an urban substation, during a single contingency event, interruption of supply up to 40MVA is permissible for the first 30 minutes, followed by a maximum interruption of up to 12MVA, provided that all load except for up to 4MVA can be restored within 3 hours, and the remaining 4MVA is fully restored within 8 hours.

Table 3 below outlines the Safety Net criteria.

Category	Demand Range	Allowed Outage to be OK
Urban	> 40MVA	No outage OK
	12-40MVA	30 minutes OK
	4-12MVA	3 hours OK
	<4MVA	8 hours OK

Table 3: Summary of Safety Net Criteria

Further to an assessment against its Safety Net obligations, Energex also undertake analysis of system capacity under normal conditions with all plant in service against the 10% PoE load.

3.2. Description of the Identified Need

3.2.1. Safety Net Non-Compliance

The existing supply to the Coomera area does not meet the Safety Net for an unplanned outage of a transformer at SSCMA. The following section outlines the substation limitations of the existing network. The system normal condition is assessed against the 10% PoE load forecast for SSCMA BSP and SSCMA and SSPPE. The 50% PoE load forecast is used for N-1 contingency analysis.

3.3. Quantification of the Identified Need

3.3.1. Safety Net Non-Compliance

SSCMA BSP Limitations

SSCMA BSP is equipped with 2 x 80MVA 110/33kV transformers. The substation capacity is limited by the transformer ratings and has a Normal Cyclic Capacity (NCC), Emergency Cyclic Capacity (ECC) and 2 Hour Emergency Capacity (2HEC) as below:

- NCC – 189.6MVA
- ECC – 100.0MVA
- 2HEC – 108.0MVA

Figure 8 shows the limitations at SSCMA BSP.




Figure 8: SSCMA BSP Load at Risk

*For consistency with previously published documents associated with this RIT-D, Energex have included the summer 2020/21 data which is now in the past.

Figure 8 indicates that there is a load at risk under contingency for an outage of a 110/33kV transformer at SSCMA BSP from 2029/30. Whilst this limitation is not the immediate focus of this FPAR, it is possible that a non-network solution that resolves or defers the limitations at either SSCMA and SSPPE may also resolve or defer the future limitation at SSCMA BSP.

It should also be noted that there is an already approved project to establish a Plant Overload Protection Scheme to reduce load below the 2HEC rating of the transformer following an outage of a transformer. The effect of this scheme has been considered in identifying the limitations for the network area.

SSCMA Limitations

SSCMA is equipped with 2 x 25MVA 33/11kV transformers. The substation capacity is limited by the transformer ratings as below:

- NCC – 59.0MVA
- ECC – 31.3MVA
- 2HEC – 33.8MVA





Figure 9: SSCMA Load at Risk

*For consistency with previously published documents associated with this RIT-D, Energex have included the summer 2020/21 data which is now in the past.

Figure 9 illustrates that there is an NCC load at risk (LAR) limitation with the existing equipment at SSCMA from 2027/28. There is also Safety Net limitation for an outage of a transformer at SSCMA from 2021/22.

To meet Energex's Safety Net obligations, SSCMA can supply up to 43.8MVA. This incorporates 31.3MVA of ECC transformer capacity, 8.5MVA of available load transfers and 4MVA of mobile generation support. Figure 10 shows the portion of the load duration curve for the forecast 11kV load of SSCMA and the available capacity at SSCMA.



*The values for SSCMA have been scaled to the 2022 peak forecast load of 46.0MVA

Figure 10: Load Duration Curve SSCMA in 2022 with Safety Net Limit

Figure 10 shows that approximately 0.05% of the time in 2021/22 the load is above the 43.8MVA limit.

As seen by the substation limitations, the load on SSCMA is forecast to increase. In order to determine how the increasing load will impact the substation, the historical load duration curve data has been scaled up to the forecast 50% PoE peak loads for future years. Figure 11 illustrates that as the load increases; the limit is surpassed for a longer duration per year. For readability, only every second year is shown.




Figure 11: Load duration curves for SSCMA for future years after limitation

Table 4 below describes the amount of time that the safety net limit is forecast to be exceeded each year, as well as the number of days per year.

Substation	Year	Forecast 50 PoE Load (MVA)	Security Standard Load At Risk (MVA)	Days/Yr Above Limit	% Time Above Limit	Hrs Over Limit
SSCMA (Coomera Zone Substation)	2020/21	45.3	1.5	1	0.03%	2.5
	2021/22	46.0	2.2	1	0.05%	4
	2022/23	46.8	3.0	2	0.06%	5.5
	2023/24	47.2	3.4	2	0.07%	6.5
	2024/25	47.8	4.0	3	0.09%	8
	2025/26	48.4	4.6	3	0.11%	9.5
	2026/27	49.0	5.2	5	0.15%	13.5
	2027/28	50.2	6.4	7	0.21%	18.5
	2028/29	51.2	7.4	9	0.31%	27
	2029/30	52.5	8.7	9	0.41%	35.5

Table 4: Forecast duration load will be at risk at SSCMA

Table 4 shows that to solve the identified need at Coomera zone substation, the non-network solution would need to provide 2.2MVA of network support, with a likely requirement for approximately 0.05% (4 hours) of the year in 2022. This will increase to 8.7MVA of network support for a likely requirement for 0.41% (35.5 hours) of the year in 2029/30.

As part of its operational strategy following a contingency, Energex will deploy 4MVA of generation using its fleet of mobile generators. In addition to the requirements above, Energex would be interested in any network support solutions that provide a cost-effective alternative to this requirement.

SSPPE Limitations

SSPPE is equipped with 2 x 25MVA 33/11kV transformers. The substation capacity is limited by the transformer ratings as below:

- NCC – 59.5MVA
- ECC – 31.3MVA
- 2HEC – 33.8MVA

Figure 12 shows the limitations at SSPPE.





Figure 12: SSPPE Load at Risk

*For consistency with previously published documents associated with this RIT-D, Energex have included the summer 2020/21 data which is now in the past.

There is no NCC load at risk (LAR) limitations with the existing equipment at SSPPE. Figure 12 shows that the 50% PoE load at SSPPE zone substation exceeds the 2-hour rating from Summer 2022/23. This type of limitation is commonly addressed by implementing a Plant Overload Protection Scheme (POPS) project at the substation, which is a relatively inexpensive solution. If this limitation is resolved, the next limitation at the substation will be from 2029/30.

Figure 13 shows the portion of the load duration curve for the forecast load of SSPPE with a safety net limit of 33.8MVA illustrated, which is the 2-hour rating of each transformer. It is evident that approximately 0.03% of the time in that year, the load is above the 33.8MVA limit.



*The values for SSPPE have been scaled to the 2023 peak forecast load of 35.2MVA

Figure 13: Load Duration Curve SSPPE in 2023 with Safety Net Limit

To show the increase in load over time, the historical load duration curve data was scaled up to the forecast 50% PoE peak loads for future years. Figure 14 illustrates that as the load increases; the limit is surpassed for a longer duration per year.




Figure 14: Load duration curves for SSPPE for future years after limitation

Final Project Assessment Report



Table 5 below outlines the amount of time that the Safety Net limit is forecast to be exceeded each year, as well as the number of days per year.

Substation	Year	Forecast 50 PoE Load (MVA)	Security Standard Load At Risk (MVA)	Days/Yr Above Limit	% Time Above Limit	Hrs Over Limit
SSPPE	2020/21	32.0	0.0	-	-	-
	2021/22	33.2	0.0	-	-	-
	2022/23	34.6	0.8	1	0.02%	1.5
	2023/24	35.8	2.0	2	0.05%	4
	2024/25	36.9	3.1	4	0.09%	7.5
	2025/26	38.1	4.3	4	0.13%	11.5
	2026/27	39.4	5.6	6	0.21%	18
	2027/28	41.0	7.2	9	0.33%	28.5
	2028/29	42.5	8.7	12	0.45%	39.5
2029/30	44.2	10.4	17	0.65%	57	

Table 5: Forecast duration load will be at risk at SSPPE

Table 5 shows that to solve the identified need at SSPPE, the non-network solution(s) will be required to provide 0.8MVA of network support, with a likely requirement for approximately 0.02% (1.5 hours) of the year in 2022/23. This will increase to 10.4MVA of network support for a likely requirement for 0.65% (57 hours) of the year in 2029/30.

As part of its operational strategy following a contingency, Energex will deploy 4MVA of generation using its fleet of mobile generators. In addition to the requirements above, Energex would be interested in any network support solutions that provide a cost-effective alternative to this requirement.

4. Network Options Identified

4.1. Do Nothing (Base Case)

The identified need is non-compliance with Energex’s Safety Net obligations outlined in Energex’s Distribution Authority. As such, the Do Nothing option is not an acceptable outcome.

4.1.1. Option 1: Establish new 25MVA 33/11kV Pimpama zone substation (SSPPA)

This option involves establishing SSPPA as 1 x 25MVA zone substation with 33kV double circuit by double tee-off from 33kV feeders F3641 and F3642 between SSCMA bulk supply and SSPPE zone substation by October 2023.

The works required to implement this option are:

- Establish a single modular or equivalent masonry building substation with a 33/11kV 25MVA transformer at SSPPA.
- Construct 1.6 km of 33kV DCCT into SSPPA with double tee-off from existing 33kV DCCT feeders, F3641 and F3642. Following detailed design, this option may become a loop-in, loop-out arrangement from one of these 33kV feeders, however this will not materially change the cost or network arrangement of this option.
- Cut over into existing 11kV feeders and establish new 11kV feeders as needed
- Establish a Plant Overload Protection Scheme at SSPPE
- Estimated capital cost: \$12.93 million ± 40%
- Estimated operating cost per annum: \$50,250

A schematic diagram of the proposed solution is shown in Figure 15 below.




Figure 15: Proposed network arrangement under option 1

It should be noted that the option to construct a single 33kV feeder to SSPPA was considered, however due to the future requirements of a second circuit and the constraints in obtaining duplicate 33kV routes, the most economical solution is to establish these feeders as a double circuit in the first instance.

4.1.2. Option 2: Establish new 25MVA 33/11kV Coomera East zone substation (SSCET)

This option involves establishing SSCET as a 1 x 25MVA zone substation by October 2023. To reduce feeder costs, the CCY21A 11kV feeder which is constructed at 33kV can be energised at 33kV and cut-in-and-out of F3640 to supply SSCET from SSCMA bulk supply, in combination with 0.4km of 33kV SCCT OH as well as 2km of 11kV OH to replace the second 11kV supply to Dreamworld.

The works required to implement this option are:

- Establish 1 x 25MVA 33/11kV single modular or equivalent masonry building substation at SSCET.
- Construct 400m of 33kV SSCT OH from SSCET to end of CCY21A.
- Build 2km of 11kV OH from end of CCY21A to CET and connect to replace Dreamworld second 11kV supply.
- Cut into F3640 and joint in P129550.
- Energise CCY21A to SSCET at 33kV.
- Reconductor, uprate and reconfigure existing 11kV network to provide optimum 11kV supply capacity to Pimpama area and provide relief to existing 11kV feeders and adjacent zone substations (SSCMA and SSPPE).
- Establish a Plant Overload Protection Scheme at SSPPE
- Estimated cost: \$13.5 million ± 40%
- Estimated operating cost per annum: \$62,600

A schematic diagram of the proposed solution is shown in Figure 16 below.

Final Project Assessment Report




Figure 16: Proposed network arrangement under option 2

It should be noted that this option is dependent on an existing 33kV feeder, energised at 11kV. Therefore a 2nd 33kV feeder is not included in this option.

4.1.3. Option 3: Upgrade SSCMA by installing a 3rd 25MVA 33/11kV transformer and associated switchgear

This option involves installing a third 25MVA 33/11kV transformer and associated switchgear at Coomera zone substation by October 2023. This option relies on building greater 11kV network capacity in the future in order to help manage the load increases in the Pimpama area.

The works required to implement this option are:

- Install 3rd 25MVA 33/11kV transformer at SSCMA.
- Install 33kV and 11kV switchgear
- Cut over 3 x 11kV feeders to the new 11kV switchgear.
- Split 11kV bus by opening section breaker (CB1X22) and implement ACO scheme for loss of TR2.
- Establish a Plant Overload Protection Scheme at SSPPE
- Estimated capital cost: \$11.96 million ± 40%
- Estimated operating cost per annum: \$2,680 (there is only a small marginal increase in operating expenditure due to the substation already being established)

A schematic diagram of the proposed solution is shown in Figure 17 below.




Figure 17: Proposed network arrangement under option 3

4.2. Preferred Network Option

Option 1 is currently the preferred network option. SSPPA is closer to most of the new developments meaning there are less costs to construct 11kV feeders to supply the new forecast loads. The scope of the preferred network option includes:

- Establish new single transformer 33/11kV modular substation or equivalent masonry building.
- Establish 2 x 33kV feeders to supply the new substation.
- Establishing a Plant Overload Protection Scheme at SSPPE.

The preferred network option has an estimated capital project cost of \$12.93M, and an annual operating cost of approximately \$50,250.

5. Summary of Submissions Received

On 21 September 2020 Energex published the NNOR providing details on the identified need at SSCMA and SSPPE. In response to the NNOR, Energex received three submissions by 21 December 2020. These responses identified two credible options:

- Establish several battery systems and/or load curtailment of customer load on various 11kV feeders.
- Establish a single battery system to allow for restoration of supply following a contingency.

On 4 May 2021 Energex published the DPAR. In response to the DPAR, Energex received two submissions from proponents that also submitted to the NNOR. These responses provided further detail and pricing from their previous submissions. These submissions identified two credible options:

- Establish multiple Battery Energy Storage Systems on multiple 11kV feeders across SSCMA and SSPPE
- Establish multiple Battery Energy Storage Systems on multiple 11kV feeders at SSCMA only

The two options identified from the submissions to the DPAR are now considered the only two credible non-network options, superseding the options previously identified from the NNOR. These two options are further explained below.

5.1. Option 4: Establish Battery Energy Systems across SSCMA and SSPPE

This option involves contracting a proponent to establish battery systems on multiple 11kV feeders, up to a value of 10MVA / 16MWh progressively delivered over the period between 2023/24 to 2027/28. A further 6MVA / 14MWh will be delivered in the period 2028/29 to 2029/30. This solution provides network support to resolve the identified limitation at SSCMA, SSPPE and potential future 11kV feeder limitations due to the connection across the network.

This option will allow for a contingency response for a transformer outage at SSCMA or SSPPE, decrease load on the 11kV feeders, thereby deferring expenditure on the 11kV network and increasing transfer capacity between SSCMA and SSPPE.

5.2. Option 5: Establish Battery Energy Systems on SSCMA only

This option involves contracting a proponent to establish battery systems connected to SSCMA, installing a series of battery systems of 3.9MW/12.1 MWh in 2022, growing to 7.25MW/20.2MWh in 2028 and to 10.45MW/29.8MWh in 2030. This solution will provide network support to SSCMA to resolve the identified Safety Net limitation and will require Energex to establish a Plant Overload Protection System at SSPPE to manage the potential small overload at SSPPE.

6. Non-Network Options

6.1. Feasible vs Non-Feasible Options

6.1.1. Potentially Feasible Options

The identified need presented in this FPAR is driven by Energex not meeting its Safety Net obligations. Specifically, an outage of an existing transformer at SSCMA zone substation leads to a Safety Net load at risk of 1.5MVA in 2020/21 which increases in future years, and an outage of a transformer at SSPPE results in 0.8MVA Safety Net load at risk in 2022/23 which also increases significantly. As such, solutions that prudently and efficiently address these constraints will be considered.

In addition, there is a forecast N-1 limitation at Coomera bulk supply from 2029 onwards which is not the focus of this FPAR and therefore not a requirement that the non-network solution/s would need to address. However, it is mentioned in this report as this security standard load at risk may be reduced or even resolved as a result of any feasible solution/s to the identified need in this report.

In respect of the requirements under 5.17.4(e)(4) of the NER, any non-network option will contribute to power system security and reliability to the extent that the solution solves the Safety Net limitation. The contribution to power system fault levels is not an issue for this limitation.

A non-exhaustive list of potentially feasible options includes:

- Embedded dispatchable network generation
- Embedded energy storage systems
- Embedded energy storage systems combined with Generation (possibly dispatchable or non-dispatchable)
- Load curtailment agreements with customers to disconnect from the network following a contingency.

It should be noted that the above options may be aggregated across multiple substations in the network. For example, embedded solutions or load curtailment options could be implemented in the supply areas of SSPPE and SSCMA to provide the required network support.

Although the Safety Net constraints must be addressed, these are minimum requirements and solutions that can provide greater capacity to the network and improved reliability and security of supply may be considered. Furthermore, if a proponent is unable to support the total load required, Energex still encourages the submission of any solutions to reduce the constraints as it may be possible to aggregate multiple proposals to address the limitation or to have a hybrid solution with a potential network solution.

6.1.2. Options That Are Unlikely To Be Feasible

Without attempting to limit a potential proponent's ability to innovate, unproven, experimental or undemonstrated technologies are unlikely to be considered as feasible options to address the identified limitation.

7. Market Benefit Assessment Methodology

The identified need outlined in the NNOR, DPAR and FPAR is a regulatory obligation to meet the Safety Net requirements outlined in the Distribution Authority. Because of this, the assessment methodology is a lowest cost process, rather than a cost/benefit analysis based on market benefits. There is no material difference in specific market benefits, such as Value of Customer Reliability, between identified Network and Non-Network Options. As such, no Market Benefits have been calculated for use in the economic analysis to identify the preferred option.

8. Detailed Economic Assessment

8.1. Methodology

Where there is a regulatory obligation to comply with the Safety Net criteria, Energex apply a lowest cost Net Present Value (NPV) assessment to determine the preferred network option. For the identified need presented in this FPAR, a Weighted Average NPV, based on a sensitivity analysis, was conducted to establish the option that remained the lowest cost option in the scenarios considered. In effect, this means that Energex create a separate NPV for each scenario, assign a weighting to each, with the outcome a Weighted Average NPV to inform the lowest cost option in a range of scenarios to proceed with.

The preferred option for this FPAR is Option 5, which was based on two submissions received in response to the NNOR. To protect Commercial-in-Confidence information, Energex has not published the economic analysis associated with the costs provided in this submission. Energex however can detail that the costs associated with this option are enough to meet the deferral value required to be the preferred option. In addition, the Weighted Average NPV is the lowest cost when comparing the non-network option to the alternative feasible Network options.

8.2. Key Variables and Assumptions

8.2.1. Discount Rate

Calculations for annual deferral values of projects are based on Energex's regulated pre-tax real Weighted Average Cost of Capital (WACC). This value is prescribed by the AER for a specific regulatory control period. The identified need described in this FPAR occurs in the 2020-2025 regulatory control period, where the WACC is 2.62%.

8.2.2. Cost Estimates

Project costs are calculated using standard estimate components which are developed and evaluated by estimation teams in Energex. The costs are split into 2 components: direct cost, which are the costs directly costed to the project; and indirect costs which cover overheads associated with the business. All costs provided in this report are estimated to fall within $\pm 40\%$ accuracy of the stated cost.

8.2.3. Evaluation Test Period

Consideration of network options is assessed over an evaluation period of 60 years.

8.3. Scenarios Adopted for Sensitivity Analysis

The scenarios that have been considered are:

- **Medium demand (base case)** – under this scenario the load forecast presented in Section [Error! Reference source not found.](#) is utilised to set the timing of the future stages in each option. In effect, this means that a new 11kV feeder has been assumed to be required to supply the new load around the Pimpama and Coomera areas every 3 years, whether this is from SSPPE, SSCMA or a new Pimpama zone substation. For Option 4, this means that the initial battery solution will be able to support the load for 10 years and would be able to extend the time required between establishing new 11kV feeders. For Option 5, the battery system only defers the need for the new substation. This scenario has been assigned a likelihood of 70% in the weighted average NPV.
- **Low demand** – under this scenario the assumption is that new 11kV feeders are required around every four years and any subsequent stages for each option shifted out accordingly. For Option 4, this means that the initial battery solution would defer the establishment of these feeders, however Energex have still assumed that the new substation is required at the end of the proposed contract period. For Option 5, the battery system only defers the need for the new substation. This scenario has been assigned a likelihood of 30% in the weighted average NPV.

8.4. NPV Results

Table 6 shows the Weighted Average NPV results for the identified options. As discussed earlier, the NPV costs results have been withheld for Options 4 and 5 as they are based on the submission to the NNOR that was received, which Energex and the proponent considers to be Commercial-in-Confidence. The costs associated with these two options are such that Option 5 is the preferred option in the Weighted Average NPV results.

Option Number	Option Name	Rank	Net Economic Benefit (\$M)	PV of CAPEX (\$M)	PV of OPEX (\$M)
1	Establish new Pimpama zone substation	3	-21,468	-19,392	-2,076
2	Establish new Coomera East zone substation	5	-27,995	-24,042	-3,953
3	Upgrade Coomera zone substation	4	-22,719	-20,439	-2,280
4	Contract multiple Battery Energy Storage Systems on SSCMA and SSPPE	2	Withheld	Withheld	Withheld
5	Contract multiple Battery Energy Storage Systems on SSCMA only	1	Withheld	Withheld	Withheld

Table 6: Weighted Average NPV Results

Further details such as project staging and the NPV results for each scenario can be found in Appendix C.

8.5. Selection of Preferred Option

Option 5 is currently the preferred option overall. Contracting a series of battery systems for 16MVA overall defers the investment in a new zone substation at Coomera and enables Energex to monitor load growth in the area. The scope of the preferred non-network option includes:

3.9MW/12.1 MWh in 2022, growing to 7.25MW/20.2MWh in 2028 and to 10.45MW/29.8MWh in 2030

- Contract 3.9MW/12.1MWh battery systems to allow for generation support under a contingency at SSCMA in the period from 2021/22 to 2023/24
- Contract a further 7.25MW/20.2MWh battery systems as load grows in the area in the period from 2023/24 to 2027/28
- Contract a further 10.45MW/29.8MWh battery systems as load grows in the area in the period from 2028/29 to 2029/30.

As previously described, Energex view the information provided as part of the submission to the DPAR as Commercial-in-Confidence and as such won't publish the capital and operating costs associated with this option.

9. Conclusion

The FPAR represents the final stage of the consultation process in relation to the application of the RIT-D.

Energex intends to take steps to progress the proposed preferred option to ensure any statutory non-compliance is addressed and undertake appropriately justified network reliability improvements, as necessary.

9.1. Satisfaction of RIT-D

The proposed preferred option satisfies the RIT-D.


This statement is made on the basis of the detailed analysis set out in this report. The proposed preferred option is the credible option that has the highest net economic benefit under the most likely reasonable scenarios.

10. Compliance Statement

This Non-Network Options Report complies with the requirements of NER section 5.17.4(e) as demonstrated below:

Requirement	Report Section
(1) a description of the identified need for investment;	3
(2) the assumptions used in identifying the identified need (including, in the case of proposed reliability corrective action, why the RIT-D proponent considers reliability corrective action is necessary);	3.2 & 3.3
(3) if applicable, a summary of, and commentary on, the submissions received on the DPAR;	5
(4) a description of each credible option assessed	4 and 5
(5) where a <i>Distribution Network Service Provider</i> has quantified market benefits in accordance with clause 5.17.1(d), a quantification of each applicable market benefit of each credible option	7
(6) a quantification of each applicable cost for each credible option, including a breakdown of operating and capital expenditure	4
(7) a detailed description of the methodologies used in quantifying each class of costs or market benefit	n/a
(8) where relevant, the reasons why the RIT-D proponent has determined that a class or classes of market benefits or costs do not apply to a credible option	7
(9) the results of a NPV analysis of each credible option and accompanying explanatory statements regarding the results	8.4
(10) the identification of the proposed preferred option	8.5
(11) for the proposed preferred option, the RIT-D proponent must provide: <ul style="list-style-type: none"> (i) details of the technical characteristics; (ii) the estimated construction timetable and commissioning date (where relevant); (ii) the indicative capital and operating costs (where relevant); (iv) a statement and accompanying analysis that the proposed preferred option satisfied the RIT-D; and (v) if the proposed preferred option is for reliability corrective action and that option has a proponent, the name of the proponent 	6

Appendix A – The RIT-D Process



Source: AEMC, *Rule determination: National Electricity Amendment (Replacement expenditure planning arrangements) Rule 2017*, July 2017, p. 64.

Appendix B – Glossary of Terms

Term	Definition
Peak Risk Period	The time period over which the load is highest (Day/Night).
NCC Rating (MVA)	<p>Normal Cyclic Capacity – the total capacity with all network components and equipment in service.</p> <p>The maximum permissible peak daily loading for a given load cycle that plant can supply each day of its life. Taking impedance mismatch into consideration, it is considered the maximum rating for a transformer to be loaded under normal load conditions.</p>
10 PoE Load (MVA)	Peak load forecast with 10% probability of being exceeded (one in every 10 years will be exceeded). Based on normal expected growth rates & weather corrected starting loads.
LARn (MVA)	Security standard load at risk under system normal condition, expressed in MVA.
LARn (MW)	Security standard load at risk under system normal condition, expressed in MW.
Power Factor at Peak Load	Compensated power factor at 50 PoE Load. Capacitive compensation is switched according to the size of the capacitor banks installed at the substation, compensation is generally limited to prevent a substation from going into leading power factor.
ECC Rating (MVA)	<p>Emergency Cyclic Capacity – the long term firm delivery capacity under a single contingent condition.</p> <p>The maximum permissible peak emergency loading for a given load cycle that an item of plant can supply for an extended period of time without unacceptable damage. For substations with multiple transformers, the ECC is the minimum emergency cyclic capacity of all transformer combinations taking impedance mismatches into consideration, with one transformer off-line.</p>
50 PoE Load (MVA)	Peak load forecast with 50% probability of being exceeded (one in every two years will be exceeded). Based on normal expected growth rates and weather corrected starting loads.
Raw LAR (MVA)	<p>The amount of load exceeding ECC rating.</p> <p>(50 PoE Load – ECC Rating)</p>
2-Hour Rating (MVA)	<p>Two-Hour Emergency Capacity (2HEC) – the short term or firm delivery capacity under a single contingent condition.</p> <p>The maximum permissible peak emergency loading for a given load cycle that an item of plant can supply up to two hours without causing unacceptable damage. For substations with multiple transformers, the 2HEC is the minimum two hour emergency rating of all transformer combinations taking impedance mismatches into consideration, with one transformer off line.</p>

Final Project Assessment Report



Term	Definition
Auto Trans Avail (MVA)	SCADA or automatically controlled load transfers that can be implemented within one minute.
Remote Trans Avail (MVA)	Load transfers that can be implemented through SCADA switching procedures by the network control officer. It is assumed that this can generally be achieved within 30 minutes excluding complex or time-consuming restoration procedures.
Manual Trans Avail (MVA)	<p>Load transfers can also be deployed via manually controlled switchgear locally by field staff. It is assumed that the implementation of manual switching procedures to isolate the faulted portion of the network to restore supply to healthy parts of the network can be fully implemented within three hours (urban) or four hours (rural).</p> <p>Manual transfers are obtained from load flow studies performed on each 11kV distribution feeder based on the forecast 2016/17 load, the sum of all available 11kV transfers at a substation is multiplied by a 0.75 factor to account for diversity and to provide a margin of error to avoid voltage collapse. The same approach applies throughout the forward planning period.</p>
LARc (MVA)	Security standard load at risk for single contingent conditions.
LARc (MW)	Estimated generation / load reduction required to defer the forecast system limitation. This is the security standard load at risk for a single contingency, expressed in MW.
Customer Category	For security standard application, the general type of customer a substation or feeder supplying the area.

Appendix C – NPV Details

Network Limitation	Component Title Selection	Stage Timing Option 1	Stage Timing Option 2	Stage Timing Option 3	Stage Timing Option 4	Stage Timing Option 5
Safety Net Limitation at SSCMA	Establish new 25MVA 33/11kV Pimpama zone substation	2023		2040	2028	2028
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPA to supply new load	2025				
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPA to supply new load	2028				
Safety Net Limitation at SSCMA	Establish 2nd Module at SSPPA	2030			2030	2030
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE	2033				
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE	2036				
Safety Net Limitation at SSCMA	Establish new 25MVA 33/11kV Coomera East zone substation		2023			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2025			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2028			
Safety Net Limitation at SSCMA	Establish 2nd Module at SSPPA		2030			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2033			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2036			
Safety Net Limitation at SSCMA	Upgrade SSCMA by installing a 3rd 25MVA transformer and associated switchgear			2023		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE to supply new load			2025		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSCMA, including 11kV underbore.			2028		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSCMA, utilising existing conduit and underbore			2033		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSCMA, utilising existing conduit and underbore			2036		
Safety Net Limitation at SSCMA	10MW Battery connected across 4 sites (7 years)				2023	
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE				2026	
Safety Net Limitation at SSCMA	5MW Battery connected at SSCMA (7 years)					
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE					2026
Safety Net Limitation at SSCMA	10MW battery and demand management connected on Coomera only feeders					2023
Safety Net Limitation at SSPPE	Establish POPS at SSPPE due to exceedance of 2 hour rating				2030	2025

Figure 18 – Project Staging for the Medium Demand Scenario

Option Number	Option Name	Rank	Net Economic Benefit (\$M)	PV of CAPEX (\$M)	PV of OPEX (\$M)
1	Establish new Pimpama zone substation	2	-22,202	-20,015	-2,188
2	Establish new Coomera East zone substation	4	-28,683	-24,630	-4,053
3	Upgrade Coomera zone substation	3	-25,210	-22,628	-2,582
4	Establish 10MW Battery across 4 sites at SSCMA and SSPPE	2	Withheld	Withheld	Withheld
5	Establish 10MW Battery across 4 sites at SSCMA only	1	Withheld	Withheld	Withheld

Table 7 – NPV Results for Medium Demand Scenario

Final Project Assessment Report



Network Limitation	Component Title Selection	Stage Timing Option 1	Stage Timing Option 2	Stage Timing Option 3	Stage Timing Option 4	Stage Timing Option 5
Safety Net Limitation at SSCMA	Establish new 25MVA 33/11kV Pimpama zone substation	2023			2033	2032
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPA to supply new load	2028			2033	
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPA to supply new load	2032			2033	2032
Safety Net Limitation at SSCMA	Establish 2nd Module at SSPPA	2036			2036	2036
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPA to supply new load	2037			2037	2037
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPA to supply new load	2042			2042	2042
Safety Net Limitation at SSCMA	Establish new 25MVA 33/11kV Coomera East zone substation		2023			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2028			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2032			
Safety Net Limitation at SSCMA	Establish 2nd Module at SSPPA		2036			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2037			
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from Coomera East zone substation		2042			
Safety Net Limitation at SSCMA	Upgrade SSCMA by installing a 3rd 25MVA transformer and associated switchgear			2023		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE to supply new load			2028		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSCMA, including 11kV underbore.			2032		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSCMA, utilising existing conduit and underbore			2037		
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSCMA, utilising existing conduit and underbore			2042		
Safety Net Limitation at SSCMA	10MW Battery connected across 4 sites (10 years)				2023	
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE				2030	
Safety Net Limitation at SSCMA	5MW Battery connected at SSCMA (10 years)					2023
80% TMU limitation at 11kV Feeders at SSPPE	11kV Feeder from SSPPE					2028
Safety Net Limitation at SSCMA	10MW battery and demand management connected on Coomera only feeders					
Safety Net Limitation at SSPPE	Establish POPS at SSPPE due to exceedance of 2 hour rating					2032

Table 8 – Project Staging for the Low Demand Scenario

Option Number	Option Name	Rank	Net Economic Benefit (\$M)	PV of CAPEX (\$M)	PV of OPEX (\$M)
1	Establish new Pimpama zone substation	2	-19,754	-17,937	-1,817
2	Establish new Coomera East zone substation	5	-26,389	-22,669	-3,720
3	Upgrade Coomera zone substation	1	-16,907	-15,331	-1,576
4	Establish 10MW Battery across 4 sites at SSCMA and SSPPE	3	Withheld	Withheld	Withheld
5	Establish 10MW Battery across 4 sites at SSCMA only	4	Withheld	Withheld	Withheld

Table 9 – NPV Results for Low Demand Scenario